

April 30, 2021

Mr. Austin F. Callwood, Director Division of Environmental Protection Department of Planning & Natural Resources 45 Mars Hill Frederiksted, V.I. 00840-4474

SUBJECT: No. 8 Flare H₂S Exceedances – April 22-23, 2021

Dear Mr. Callwood:

This letter is submitted in compliance with Condition No. 2.4.5.1 of Limetree Bay Title V permit as a follow-up to the email notifications to Ms. Verline Marcellin of the Division of Environmental Protection on April 23, 2021 at 10:04 AM regarding the H₂S exceedances at the No. 8 Flare.

The Continuous Emissions Monitoring System (CEMS) recorded H₂S concentrations in the No. 8 Flare header in excess of 0.1 gr/dscf (162 ppm) based on a 3-hr rolling average (ref. Title V permit condition 3.2.5.5 & 3.2.5.6) from April 22, 2021 to April 23, 2021.

The following table provides 3-hr H₂S concentrations at the No. 8 Flare during the exceedance event.

Source Parameter Unit		FLARE08	Source Parameter Unit		FLARE08 H2SPPMD (PPM)	Source Parameter Unit		FLARE08 H2SPPMD (PPM)
		H2SPPMD (PPM)						
04/22/21	17:00	39.4	04/23/21	04:00	2,505.2	04/23/21	15:00	7,459.6
04/22/21	18:00	39.4	04/23/21	05:00	2,590.8	04/23/21	16:00	5,971.0
04/22/21	19:00	39.4	04/23/21	06:00	2,626.7	04/23/21	17:00	7,167.0
04/22/21	20:00	39.4	04/23/21	07:00	3,636.7	04/23/21	18:00	6,291.3
04/22/21	21:00	532.3	04/23/21	08:00	20,495.0	04/23/21	19:00	5,226.0
04/22/21	22:00	1,030.0	04/23/21	09:00	55,482.2	04/23/21	20:00	3,428.2
04/22/21	23:00	1,543.7	04/23/21	10:00	85,449.0	04/23/21	21:00	2,767.3
04/23/21	00:00	1,526.8	04/23/21	11:00	91,649.0	04/23/21	22:00	1,757.9
04/23/21	01:00	1,722.6	04/23/21	12:00	61,742.3	04/23/21	23:00	797.7
04/23/21	02:00	1,958.0	04/23/21	13:00	33,498.8	04/24/21	00:00	90.2
04/23/21	03:00	2,324.7	04/23/21	14:00	11,174.2	04/24/21	01:00	62.2

At approximately 4:45 AM on April 23, 2021, the No. 4 Sulfur Recovery Unit (4SRU) tripped due to both "fire-eye" flame scanners not detecting a flame. At about 5:29 AM, the 4SRU was re-lit and at 7:07 AM the Clean Acid Gas (CAG) control valve at 4SRU started to slowly open but not quick enough to alleviate the pressure in the CAG header. Due to the backpressure in the CAG header, a pressure safety valve (PSV) at the No. 5 Amine Regeneration Unit (5ARU) relieved to the No. 8 Flare. The SO₂ generated from the combustion of H₂S in the flare header caused odors which impacted our neighbors. Further investigation showed that there was another malfunctioning PSV at the No. 6 Distillate Desulfurizer Unit (DD6), contributing to the elevated H₂S before the 4SRU trip event. The PSV was taken out of service for maintenance.

To immediately reduce the H₂S in the flare header, the following corrective actions were implemented:

- H₂S producing units were shutdown or placed on circulation to reduce the load on the amine regeneration system and the sulfur plant.
- 5ARU was shut down because the PSV continued to leak to the flare even below the PSV setpoint.
- Respond to odor complaints.



Operations have implemented or are in the process of implementing the following measures including, but not limited to:

- Implement the H₂S load shed procedure Completed;
- Run both 3SRU and 4SRU at the same time, where the lead SRU receives CAG or Ammonia Acid Gas and the lag SRU is on standby in the event the lead SRU trips Completed;
- Manufacturer (Honeywell) scheduled to investigate and tune the existing "fire-eye" flame scanners
 In progress;
- Program SRU "fire-eye" scanner delay times for both SRUs In Progress
- Re-range three pressure transmitters in the amine regeneration units and SRUs to 10psi above PSV setpoints – Completed;
- Add electronic indication of acid gas inlet chopper valves in the plant's control system and plant historian database – In progress

If you have any questions or need additional information, please contact Maria Aloyo at (340) 692-3781.

Sincerely,

Neil Morgan

VP, Refinery and General Manager Limetree Bay Refining, LLC

Electronic copy: Verline Marcellin (DPNR)